304 Series™

LED Interior Recessed Luminaire

Product Description

High performance energy efficient LED down light, designed for use in drop ceilings with 20-24" (508-610mm) on center building construction. Luminaire mounts to 2' x 2' (0.6m x 0.6m) heavy gauge steel tile allowing it to be mounted directly into grid ceiling systems. Tile includes mounting slots to allow for bailing wire, as required by local code. Slim, low profile design. Luminaire is constructed from die cast and extruded aluminum components. LED driver is mounted in a sealed weather-tight center chamber that allows for access from below the luminaire. High performance heat sinks specifically designed for LED recessed applications

Applications: Interior high-bay or low-bay, convenience stores, warehouses and gymnasiums

Performance Summary

Patented NanoOptic® Product Technology

Made in the U.S.A. of U.S. and imported parts


CRI: Minimum 70 CRI

CCT: 4000K (+/- 300K), 5700K (+/- 500K) standard

Limited Warranty⁺: 10 years on luminaire/10 years on Colorfast DeltaGuard[®] finish

*See http://lighting.cree.com/warranty for warranty terms





LED Count (x10)	Weight
04	22.0 lbs. (10.0kg)
06	22.0 lbs. (10.0kg)

Ordering Information

Example: INT 304 5M RM 04 E UL WH 350 IC

INT 304		RM		E				
Product	Optic	Mounting	LED Count (x10)	Series	Voltage	Color Options	Drive Current	Options
INT 304	5M Type V Medium 5S Type V Short PS Petroleum Symmetric SL Sparkle Petroleum 40 40° Flood	RM Recessed	04 06 - Available on Non-IC rated product only	E	UL Universal 120-277V - Available on IC rated product only UH Universal 347-480V - Available on IC rated product only 12 120V - Available on Non-IC rated product only 27 277V - Available on Non-IC rated product only	BK Black BZ Bronze SV Silver WH White	350 350mA 525mA - Available on Non-IC rated product only 700mA - Available on Non-IC rated product only - Available with 40 LEDs	40K 4000K Color Temperature - Minimum 70 CRI - Color temperature per luminaire DIM 0-10V Dimming - Control by others - Refer to Dimming spec sheet for details - Can't exceed specified drive current F Fuse - When code dictates fusing, use time delay fuse - Refer to ML spec sheet for availability with ML options - Available with UL voltage only IC Type IC Rated ML Multi-Levet - Refer to ML spec sheet for details PML Programmable Multi-Levet - Refer to MML spec sheet for details PINL Programmable fullity applications at 0° tilt





Rev. Date: V2 10/04/2018



Canada: www.cree.com/canada

Product Specifications

CONSTRUCTION & MATERIALS

- High performance energy efficient LED down light, designed for use in drop ceilings with 20-24" (508-610mm) on center building construction
- Luminaire mounts to 2' x 2' (0.6m x 0.6m) heavy gauge steel tile allowing it to be mounted directly into grid ceiling systems
- Tile includes mounting slots to allow for bailing wire, as required by local code
- Slim, low profile design
- Luminaire constructed from rugged die cast and extruded aluminum ٠ components
- · LED driver is mounted in a sealed weathertight center chamber allowing access from below the luminaire
- · High performance heat sinks specifically designed for LED recessed applications
- Exclusive Colorfast DeltaGuard® finish features an E-Coat epoxy primer with an ultradurable powder topcoat, providing excellent resistance to corrosion, ultraviolet degradation and abrasion. Black, bronze, silver, and white are available
- Weight: See Weight Chart on page 1

ELECTRICAL SYSTEM

- Input Voltage: 120-277V or 347-480V, 50/60Hz, Class 1 drivers
- Power Factor: > 0.9 at full load
- Total Harmonic Distortion: < 20% at full load •
- Integral 10kV surge suppression protection standard
- To address inrush current, slow blow fuse or type C/D breaker should be used
- 10V Source Current: 0.15mA
- Operating Temperature Range: IC: 350mA: -40°C +30°C [-40°F - +86°]; Non-IC: 350mA: -40°C - +50°C (-40°F - +122°); 525mA: -40°C - +40°C (-40°F - +104°); 700mA: -40°C - +30°C (-40°F - +86°)

REGULATORY & VOLUNTARY QUALIFICATIONS

- cULus Listed
- Suitable for wet locations
- Suitable for through wiring
- Meets FCC Title 47 CFR Part 15, Non-Consumer EMI and RFI emission levels
- 10kV surge suppression protection tested in accordance with IEEE/ANSI • C62.41.2
- Luminaire and finish endurance tested to withstand 5,000 hours of elevated ambient salt fog conditions as defined in ASTM Standard B 117
- · Meets Buy American requirements within ARRA
- RoHS compliant. Consult factory for additional details
- CA RESIDENTS WARNING: Cancer and Reproductive Harm -www.p65warnings.ca.gov

Electrical Data*								
LED Count (x10) System Watts 120-480V	System	Total Cur	Total Current					
	Watts 120-480V	120V	208V	240V	277V	347V	480V	
350mA								
04	46	0.39	0.24	0.22	0.21	0.15	0.12	
06	69	0.57	0.34	0.30	0.27	0.21	0.16	
525mA								
04	71	0.59	0.35	0.31	0.28	0.21	0.16	
06	101	0.84	0.49	0.43	0.38	0.30	0.22	
700mA								
04	94	0.79	0.46	0.40	0.36	0.28	0.21	

* Electrical data at 25°C (77°F)

Recommended 304 Series™ Lumen Maintenance Factors (LMF) ¹						
Ambient	Drive Current	Initial LMF	25K hr Projected ² LMF	50K hr Projected ² LMF	75K hr Projected ² LMF	100K hr Calculated ³ LMF
	350mA					
5°C (41°F)	525mA	1.04	0.99	0.97	0.95	0.93
	700mA					
	350mA					
10°C (50°F)	525mA	1.03	0.98	0.96	0.94	0.92
	700mA					
	350mA					
15°C (59°F)	525mA	1.02	0.97	0.95	0.93	0.91
	700mA					
	350mA					
20°C (68°F)	525mA	1.01	0.96	0.94	0.92	0.90
	700mA					
	350mA					
25°C (77°F)	525mA	1.00	0.95	0.93	0.91	0.89
	700mA]				


¹ Lumen maintenance values at 25°C (77°F) are calculated per TM-21 based on LM-80 data and in-situ luminaire testing ²In accordance with IESNA TM-21-11, Projected Values represent interpolated value based on time durations that are within six times (8) the IESNA LM-80-08 total test duration (in hours) for the device under testing ([DUT] i.e. the packaged LED chip) ³In accordance with IESNA TM-21-11, Calculated Values represent time durations that exceed six times (8) the IESNA IM 000 extended the test duration test is the test duration of the test is the test of the test in the test is the test of the test of the test is the test of the test of the test is the test of the test of test is the test of test is the test of test is the test of test of test is the test of test of test of test is the test of test of test of test is the test of te

LM-80-08 total test duration (in hours) for the device under testing ([DUT) i.e. the packaged LED chip



All published luminaire photometric testing performed to IESNA LM-79-08 standards by a NVLAP accredited laboratory. To obtain an IES file specific to your project consult: http://lighting.cree.com/products/indoor/high-bay-low-bay/304-series

5M



INT 304 5M ** 06 E UL 525 40K Based on ITL Test Report #: 78147 Initial Delivered Lumens: 12,508

Coefficients Of Utilization - Zonal Cavity Method				
RC %:	80			
RW %:	70	50	30	10
RCR: 0	119	119	119	119
1	104	97	91	85
2	90	79	69	61
3	79	65	54	45
4	70	55	43	34
5	63	47	35	27
6	57	41	30	22
7	53	36	26	18
8	49	32	22	15
9	45	29	20	13
10	42	27	18	11

Type V Medi	um Distribution	
	4000K	5700K
LED Count (x10)	Initial Delivered Lumens*	Initial Delivered Lumens*
350mA IC Rat	ed	
04	4,291	4,456
350mA Non-I	C Rated	
04	4,516	4,690
06	6,651	6,907
525mA Non-I	C Rated	
04	6,323	6,566
06	9,311	9,669
700mA Non-I	C Rated	
04	7,678	7,973

Effective Floor Cavity Reflectance: 20%

Average Luminance Table (cd/m ²)							
Horizontal Angle							
	0°	45°	90°				
45°	30,415	35,525	30,060				
55°	61,800	64,775	62,412				
65°	121,907	98,868	119,948				
75°	117,516	124,206	115,285				
85°	40,599	22,027	31,817				
	45° 55° 65° 75°	Horizont 0° 45° 30,415 55° 61,800 65° 121,907 75° 117,516	Horizontal Angle 0° 45° 30,415 35,525 55° 61,800 64,775 65° 121,907 98,868 75° 117,516 124,206				


* Initial delivered lumens at 25°C (77°F)

Zonal Lumen Summary				
Zone	Lumens	% Lamp	Luminaire	
0-30	732	N/A	7.9%	
0-40	1479	N/A	16.0%	
0-60	4473	N/A	48.0%	
0-90	9311	N/A	100%	
0-180	9311	N/A	100%	



All published luminaire photometric testing performed to IESNA LM-79-08 standards by a NVLAP accredited laboratory. To obtain an IES file specific to your project consult: http://lighting.cree.com/products/indoor/high-bay-low-bay/304-series

5S



INT 304 5S ** 06 E UL 525 40K Based on ITL Test Report #: 77876 Initial Delivered Lumens: 12,738

Coefficients Of Utilization - Zonal Cavity Method				
RC %:	80			
RW %:	70	50	30	10
RCR: 0	119	119	119	119
1	107	101	96	92
2	94	84	76	69
3	83	71	61	53
4	74	60	49	41
5	67	51	41	33
6	60	45	34	26
7	55	39	29	22
8	51	35	25	18
9	47	31	22	16
10	44	29	20	14

Type V Shor	t Distribution	
	4000K	5700K
LED Count (x10)	Initial Delivered Lumens'	Initial Delivered Lumens'
350mA IC Rat	ed	
04	4,768	4,952
350mA Non-I	C Rated	
04	5,018	5,211
06	7,390	7,674
525mA Non-I	C Rated	
04	7,025	7,295
06	10,346	10,744
700mA Non-I	C Rated	
04	8,859	8,531

Effective Floor Cavity Reflectance: 20	%

Average Luminance Table (cd/m²)								
	Horizontal Angle							
		0°	45°	90°				
ngle	45°	50,299	48,441	51,171				
Vertical Angle	55°	89,959	108,814	84,851				
Vertio	65°	118,658	121,962	115,321				
	75°	25,442	65,219	31,419				
	85° 2,356 4,712 1,414							


* Initial delivered lumens at 25°C (77°F)

Zonal Lumen Summary				
Zone	Lumens	% Lamp	Luminaire	
0-30	941	N/A	9.1%	
0-40	1,983	N/A	19.2%	
0-60	6,577	N/A	63.6%	
0-90	10,346	N/A	100%	
0-180	10,346	N/A	100%	



All published luminaire photometric testing performed to IESNA LM-79-08 standards by a NVLAP accredited laboratory. To obtain an IES file specific to your project consult: http://lighting.cree.com/products/indoor/high-bay-low-bay/304-series

PS



INT 304 PS ** 06 E UL 525 40K Based on ITL Test Report #: 76940 Initial Delivered Lumens: 13,581

Coefficients Of Utilization - Zonal Cavity Method				
RC %:	80			
RW %:	70	50	30	10
RCR: 0	119	119	119	119
1	111	108	104	101
2	103	96	91	86
3	95	86	79	73
4	87	77	69	63
5	81	69	61	55
6	74	62	54	48
7	69	56	48	42
8	64	51	43	38
9	60	47	39	34
10	56	43	35	30

Effective Floor Cavity Reflectance: 20%

0°

65,750

59,591

2,951

1,116

452

Vertical Angle 45°

55°

65°

75°

85°

Average Luminance Table (cd/m²)

Horizontal Angle

45°

90,104

100,348

6,895

913

301

90°

66,492

59,431

3,106

1,217

452

Petroleum Symmetric Distribution					
	4000K	5700K			
LED Count (x10)	Initial Delivered Lumens*	Initial Delivered Lumens*			
350mA IC Rat	ted				
04	4,874	5,062			
350mA Non-I	C Rated				
04	5,130	5,327			
06	7,554	7,844			
525mA Non-I	525mA Non-IC Rated				
04	7,181	7,458			
06	10,576	10,982			
700mA Non-IC Rated					
04	8,720	9,056			

* Initial delivered lumens at 25°C (77°F)t

Zonal Lumen Summary				
Zone	Lumens	% Lamp	Luminaire	
0-30	3,259	N/A	30.8%	
0-40	5,690	N/A	53.8%	
0-60	10,293	N/A	97.3%	
0-90	10,576	N/A	100%	
0-180	10,576	N/A	100%	




CRE	
т (800) 473-1234	F (800) 890-7507

US: lighting.cree.com

All published luminaire photometric testing performed to IESNA LM-79-08 standards by a NVLAP accredited laboratory. To obtain an IES file specific to your project consult: http://lighting.cree.com/products/indoor/high-bay-low-bay/304-series

40°



INT 304 40 ** 06 E UL 525 40K Based on ITL Test Report #: 78011 Initial Delivered Lumens: 12,497

Coefficients Of Utilization - Zonal Cavity Method				
RC %:	80			
RW %:	70	50	30	10
RCR: 0	119	119	119	119
1	113	110	108	105
2	107	102	98	94
3	102	95	90	86
4	96	88	83	78
5	91	83	76	72
6	86	77	71	67
7	82	73	66	62
8	78	68	62	58
9	74	64	58	54
10	71	61	55	51

40° Flood Distribution					
	4000K	5000K			
LED Count (x10)	Initial Delivered Lumens'	Initial Delivered Lumens'			
350mA IC Rat	ed				
04	4,768	4,952			
350mA Non-I	350mA Non-IC Rated				
04	5,018	5,211			
06	7,390	7,674			
525mA Non-IC Rated					
04	7,025	7,295			
06	10,346	10,744			
700mA Non-I	700mA Non-IC Rated				
04	8,531	8,859			

	Horizontal Angle				
		0°	45°	90°	
Vertical Angle	45°	25,142	31,417	26,642	
	55°	11,435	11,824	11,726	
	65°	4,590	4,623	4,325	
	75°	1,456	1,510	1,564	
	85°	641	320	480	

Effective Floor Cavity Reflectance: 20%

* Initial delivered lumens at 25°C (77°F)

Zonal Lumen Summary				
Zone	Lumens	% Lamp	Luminaire	
0-30	6,882	N/A	66.5%	
0-40	8,854	N/A	85.6%	
0-60	10,194	N/A	98.5%	
0-90	10,346	N/A	100%	
0-180	10,346	N/A	100%	

© 2018 Cree, Inc. All rights reserved. For informational purposes only. Content is subject to change. Patent www.cree.com/patents. Cree®, the Cree logo, NanoOptic®, and Colorfast DeltaGuard® are registered trademarks, and 304 Series™ is a trademark of Cree, Inc. The UL logo is a registered trademark of UL LLC.

